


- FOOTING A 6'-0"X6'-0"X14" W/ 7 #5 E.W.
  - FOOTING B 5'-6"X5'-6"X14" W/ 6 #5 E.W.
  - FOOTING C 7'-0"X7'-0"X18" W/ 6 #6 E.W.
  - FOOTING D 8'-6"X8'-6"X20" W/ 7 #7 E.W.
  - FOOTING E 8'-6"X8'-6"X18" W/ 8 #5 E.W.(\*)
  - FOOTING F 9'-0"X9'-0"X22" W/10 #6 E.W.(\*)
  - FOOTING G 5'-0"X5'-0"X12" W/5#5 E.W.(\*)
- (\*) WITH 16"X16" PIER SEE TYP. DETAIL
- COLUMN A: HSS 10X10X5/16 W/BASE PLATE 1"X16"X1'-2" W/4-3/4"X1'-2" A-B
  - COLUMN B: HSS 10 X10 X 5/16" W/ BASE PLATE 1 1/4 X 16 X 1'-4" W/ 4-1/2" X 1'-6" ANCHOR BOLT
- SF DENOTES STEP FOOTING

- 1 - Refer to architectural drawings for location of columns.
- 2 - Slab on grade shall be 5" thick, 3500 psi normal weight concrete placed on 6" of washed gravel and 6 mil. vapor barrier. Reinforced with two layers of 6X8 - W4.0 X W4.0. Alternate slab on grade shall be trap rock system minimum 7" thick with #4@19" O.C. Place slab on 6 mil vapor barrier and 6" gravel.
- 3 - Footings and slab on grade shall be placed as per specifications and soil consultants report.
- 4 - Bottom of all exterior footings shall be minimum 2'-6" below finish grade.
- 5 - Centerline of columns shall be at centerline footings unless otherwise shown on drawings.
- 6 - See architectural and mechanical drawings for floor, trench drains, sump pits and verify top of footing elevations.
- 7 - For notes and further information see structural notes.
- 8 - Elevations shown on plan refers to bottom of footing.
- 9 - Footing elevation along aline shall be adjusted to provide 2H to 1V between invert of drainage pipe & bottom of footing.

**PARTIAL FOUNDATION PLAN**  
SCALE: 1/8" = 1'-0"



No.	Description	Date	No.	Description	Date	No.	Description	Date
1	FOR PERMIT ONLY	04/06/06						
Revisions								

**CKL ARCHITECTS, INC.**  
 Architecture  
 Space Planning  
 Urban Design  
 15932 C Shady Grove Road  
 Gaithersburg, MD 20877  
 Tel: 301.258.4560  
 Tel: 301.258.4562

Drawn By: LEVITA  
 Designed By: ET  
 Checked By: ET  
 Approved By: ET  
 Scale:

**PARTIAL FOUNDATION PLAN (1/8" = 1'-0")**  
 BEST FOOD COMPANY  
 SPRINGFIELD, VA

ET&A CONSULTING, INC.  
 10770 RHODE ISLAND AVENUE  
 BELTSVILLE, MD 20705  
 301-931-9130

Project No.  
 Drawing Number  
**05202**