

- 3. EXPOSED CONCRETE
1ST COAT THOROUGH OR APP'D EQUAL 2
2ND COAT THOROUGH OR APP'D EQUAL
- 4. ALL FIRE HOBRANTS AND HOSE CABINETS 2
- 5. UNDERFOOT ITEMS (DRAINS, MANHOLE COVERS AND CHIMNEYS) PRIME & 2
- B. INTERIOR PAINTING
- 1. MISC. IRON TOUCH-UP & 1
- 2. METAL STAIRS AND HANDRAILS TOUCH-UP & 1
- 3. METAL DOOR AND FRAMES 2
HOLLOW METAL
ROLLING STEEL (INCLUDING GALV. IRON SLATS WITH PRIME COAT)
- 4. EXPOSED CONCRETE BLOCK (WITH FILLER) 2
- 5. CONCRETE 2
- 6. GYPSUM WALLBOARD PARTITIONS & CEILINGS PRIME & 2
- 7. EXPOSED PIPING (BARE OR INSULATED) 2
- 8. EXPOSED DUCTWORK (BARE OR INSULATED) 2
(1ST COAT OF COLORED GALV. METAL PRIMER)
- 9. CONNECTOR COVERS 2
- 10. GRILLES, VENTS AND REGISTERS 2
- 11. EXPOSED SURFACES OF MESH & ELEC. PANELS 2
- C. MISCELLANEOUS PAINTING
- 1. COLOR OF PIPING SHALL BE PAINTED AS FOLLOWS OR DIRECTED BY THE OWNER:
COOLING AND COLLED WATER - LIGHT GREEN
COMPRESSED AIR - BLUE
GAS AND FUEL OIL - ORANGE
SPRINKLER - RED
DOMESTIC WATER HOT WATER AND CITY WATER - YELLOW
DUCT WORKS - BUFF
- 2. A COLOR COATING SHALL BE PROVIDED FOR ALL PIPING, PIPE COVERING, DUCTWORK, CONDUIT, ETC., WHETHER PAINTED OR UNPAINTED, IN FINISHED AND OTHERWISE UNFINISHED AREAS. ALL REQUIRED COATING IDENTIFICATION SUCH AS NAMING OR STICKLING ON PIPES, FACES OR INSULATION SHALL BE PROVIDED BY TRADE CONTRACTOR AS PER ANSI AND OSHA.

DIVISION 11: EQUIPMENT

SECTION 11100. LOADING DOCK EQUIPMENT

GENERAL

A. THIS UNIT SHALL MEET WITH OR EXCEED FEDERAL OCCUPATIONAL SAFETY AND HEALTH ACT STANDARD REQUIREMENTS FOR DOOR DOCK BOARDS DATED JUNE 27, 1974, AND THE AMERICAN SOCIETY OF MECHANICAL ENGINEERS SPECIFICATION ANSI MH4.1-1984.

MANUFACTURERS

A. BY CHALFANT OR APPROVED EQUAL.

ARCHITECTURAL SPECIFICATIONS

DOCK BUMPER

A. FORMED STEEL BUMP BLOCKS FACED WITH 8"X12"X3/8" LAMINATED RUBBER DOCK BUMPER W/ STEEL FRAMES TO PROTECT DOCK FACE.

- 1. TO BE SECURELY WELDED TO STEEL ANGLES OR INSERT EMBEDDED IN THE FACE OF LOADING PLATFORM.
- 2. L.A.S. TO BE PROVIDED BY COURTESY CORP. NORWALK OH. OR EQUAL.

DOCK SEAL AND SHELTER

A. TO FORM AN AIR TIGHT SEAL BETWEEN THE TRUCK AND BUILDING.

- 1. SEAL 2202 VINYL FACE, FOAM DEPTH TO WORK W/ DOCK BUMPER DEPTHA A REFERED SEAL IS RECOMMENDED 1" AT BOTTOM AND 1 1/2" AT TOP.
- 2. DOCK SEAL SHALL BE MODEL 15191 AS PROVIDED BY W.B. MAGUIRE COMPANY HUDSON, NY TO FIT DOOR OPENING 8'-0"X14'-0" (7'0"X14'-0").
- 3. COLOR OF DOCK SEAL TO BE SELECTED AT SHOP DRAWING SUBMITTAL OF MANUFACTURER.

ARCHITECTURAL ALTERNATE ITEMS:

- 1. OVERHEAD DOORS 8'-0"X20'-0" IN LIEU OF CONCRETE HOOK PANEL (UNIT PRICE)
- 2. DOCK SEAL FOR EACH DOOR (UNIT PRICE)
- 3. WOOD PANEL IN LIEU OF SPOUSE LINES ON PANEL ABOVE OVERHEAD DOOR (UNIT PRICE)

TO ASSURE THE QUALITY OF THE MATERIALS TO BE USED IN THE PROJECT, THE RIGHT IS RESERVED TO INVOKE THE MATERIAL TESTING PROCEDURE AT ANY TIME AND ANY NUMBER OF TIMES DURING THE PERIOD OF FIELD PAINTING. THE ENGAGED INDEPENDENT TESTING LABORATORY WILL PERFORM APPROPRIATE TESTS FOR PAINT OR ALL CHARACTERISTICS OF MATERIALS TO BE USED IN THE PROJECT. IF TEST RESULTS SHOW THAT THE MATERIAL BEING USED DOES NOT COMPLY AS SPECIFIED OR DIRECTED, STOP THE PAINTING WORK, REMOVE ALL NON-COMPLYING PAINT, PAY FOR TESTING AND REPAINT SURFACES COATED WITH THE REJECTED PAINT WITH APPROVED MATERIALS.

DIVISION 10: SPECIALTIES

FIRE EXTINGUISHERS, CABINETS AND ACCESSORIES

- 1. SECTION INCLUDES
FIRE EXTINGUISHERS
- 2. MANUFACTURERS
A. ALL MANUFACTURED PRODUCT COMING TOE WITH MESH WALL BRACKET, MOUNTER HOOK AND COMPANY PRODUCT MODEL TO TAG WITH BRACKET, LARSON MANUFACTURING CO. PRODUCT MODEL MP10 WITH BRACKET.
- 3. EXTINGUISHERS
A. DRY CHEMICAL TYPE UL 299, CAST STEEL TANK, WITH PRESSURE GAGE, CLASS B/C, SIZE 10.
- 4. INSTALL IN ACCORDANCE WITH MANUFACTURER'S INSTRUCTIONS AS LOCATED BY THE EQUIPMENT DRAWINGS.
- 5. PROTECTION & CLEANING
CONTRACTOR SHALL PROTECT AND CLEAN ALL O.F.C.I. ITEMS, TREATING THEM THE SAME AS IF THEY HAD BEEN PURCHASED BY THE CONTRACTOR.

TOILET PARTITIONS

- 1. PROVIDE FLOOR MOUNTED METAL TOILET PARTITIONS WHERE SHOWN ON DRAWINGS. PROVIDE A COMPLETE AND PROPER INSTALLATION AS PER MANUFACTURER'S RECOMMENDATIONS AND SPECIFICATIONS.
- 2. CONTRACTOR SHALL PROVIDE SHOP DRAWINGS WITH SUFFICIENT DETAILS TO SHOW FABRICATION, INSTALLATION AND FINISHES FOR APPROVAL.
- 3. TOILET PARTITIONS AND URINAL SCREENS SHALL BE OF THE FOLLOWING DIMENSIONS:
A. DOOR PANEL - NOT LESS THAN 1" THICK WITH 20 GA STEEL.
B. PARTITIONS - NOT LESS THAN 1" THICK WITH 20 GA STEEL.
C. PLASTER - NOT LESS THAN 1 1/4" THICK WITH 20 GA STEEL.
- 4. TYPE OF PARTITIONS:
FLOOR MOUNTED WITH 60" HIGH PANELS AND 12" ABOVE FINISHED FLOOR.
- 5. FINISH OF PARTITIONS:
GRAVED ENAMEL IN COLORS SELECTED BY OWNER FROM STANDARD COLORS OF THE APPROVED MANUFACTURER.
- 6. STANDARD MOUNTING DIMENSIONS:
A. TYPICAL STALL WIDTH 32" TO 36" CENTER TO CENTER UNLESS INDICATED OTHERWISE ON DRAWINGS OR SPECIFICATIONS.
B. BARRIER-FREE (HANDICAPPED) STALL WIDTH 60" (MIN.) CLEAR.
C. ALL STALL DEPTH SHALL BE 60".
D. TYPICAL STALL DOORS SHALL BE 34" WIDE (MIN.) WITH DOORS THAT SWING INTO STALL.
E. BARRIER-FREE STALL DOOR SHALL BE 34" WIDE (MIN.) WITH DOORS THAT SWING OUT OF STALL.
- 7. URINAL SCREEN SHALL BE 16" TO 24" WIDE AND 42" HIGH, MOUNTED 12" ABOVE FINISHED FLOOR, HAVING A THICKNESS OF 1" (MIN.)
- 8. TOILET PARTITIONS SHALL BE COMPLETE WITH APPROVED MANUFACTURER'S HARDWARE PACKAGE.
- 9. INSTALLATION OF HARDWARE SHALL INCLUDE TOILET PAPER DISPENSERS, COAT HOOKS, GRAB BARS, IN BARRIER-FREE PARTITIONS ONLY OR OTHER ITEMS INDICATED ON DRAWINGS OR GENERAL NOTES.
- 10. ACCEPTABLE TOILET STALL VENDOR:
A. "ANDERBROOK" - TYPE: NEW YORKER
B. "ALORA" - TYPE: ENDURANT
C. "AMMANTAL" - TYPE: NORMANDE
SHOP DRAWINGS AND SAMPLES ARE REQUIRED FOR REVIEW.

TOILET ACCESSORIES

- 1. PROVIDE TOILET ACCESSORIES WHERE INDICATED ON DRAWINGS AND SPECIFICATIONS.
- 2. PROVIDE PROPER BLOCKING AS REQUIRED FOR ITEMS IN NEED OF REINFORCING WITHIN WALL. CONTRACTOR SHALL COORDINATE WITH PARTITION MANUFACTURER FOR BLOCKING LOCATIONS.
- 3. INSTALL EACH ITEM IN ITS PROPER LOCATION, FIRMLY ANCHORED INTO POSITION, LEVEL AND PLUMB, AND IN ACCORDANCE WITH ADA STANDARDS AND MANUFACTURER'S RECOMMENDATIONS.
- 4. ACCEPTABLE TOILET ACCESSORIES MANUFACTURERS:
A. BRYBRICK WASHROOM EQUIPMENT, INC.
B. BRADLEY CORP.
C. AMERICAN SPECIALTIES, INC.

No.	Description	Date	No.	Description	Date	No.	Description	Date
		10/26/2005						

CKL
ARCHITECTS, INC.
Architecture
Space Planning
Urban Design
15932 C Shady Grove Road
Gaithersburg, MD 20877
Tel: 301.258.4560
Tel: 301.258.4560

Drawn By:	RL
Designed By:	IKL
Checked By:	IKL
Approved By:	IKL
Scale:	

Notes

Title	SPECIFICATION
Project No.	
Drawing Number	
BEST WAREHOUSE LORTON DEVELOPED BY BEST WU'S L.L.C 9525 GUNSTON COVE ROAD	

SP-3